


DE SECURITATE LA INCENDIU  
 I.S.U. Timisoara  
 Nr. 233/18  
 02.10.2018



Ing. Tiber DEZSI	Ing. Florin BLENDEA	13.11.17
PROIECTANT / DESIGNY	VERIFICANT / APROBAT	DATA
Nr. Proiect: 2873	Scara: %	
Nr. Planşa: 3/3	Faza: PT+DEE	
Data: 13.11.2017	Revizor:	0

0 | PRIMA DIFUZARE  
 REV / DESCRIERE  
 Sistem de detectie semnalizare si avertizare incendii.  
 Schema Bloc.  
 Beneficiar: Spitalul "Dr. Karl Dief", Jimbolia  
 ICGO Systems  
 SPMF Sca. Herman Obert, nr. 25, Ghimbav, Jud. Cluj, Romania, Tel: 0364.422642

LEGENDA	
DG.0	Detector de gaz
DM.0	Detector multicriterii de fum
BI.0	Buton de avertizare incendiu
3/IO.0	Modul 3 intrari o iesire
4/IO.0	Modul 4 intrari 2 iesiri
SIL.0	Sirena de avertizare incendiu (interior)
SIE.0	Sirena de avertizare incendiu (exterior)
ECS.0	Centrala de detectie incendii
S.A.0	Sursa de alimentare
	Cablu incendiu 2x2x0.8 (Buclia 1)
	Cablu incendiu 2x2x0.8 (Buclia 2)
	Traseu fibra optica
	Sufa metalica